

ENERGY AUDIT - 2023



COCHIN UNIVERSITY OF SCIENCE & TECHNOLOGY

KALAMASSERY, ERNAKULAM

EXECUTED BY



ATHUL ENERGY CONSULTANTS PVT LTD

4th FLOOR, CAPITAL LEGEND BUILDING,

KORAPPATH LANE, ROUND NORTH, THRISSUR-680020

Ph: +91 7356111990-6 Web: www.athulenergy.com E-Mail: info@athulenergy.com

March 2023

**TABLE OF CONTENTS**

PREFACE	6
ACKNOWLEDGEMENTS	7
EXECUTIVE SUMMARY	8
I. ENERGY SAVING PROPOSALS	8
II. PRESENT ANNUAL ENERGY CONSUMPTION	9
III. PRESENT ANNUAL ENERGY COST	9
IV. ENERGY AUDIT SUMMARY & RECOMMENDATIONS	10
V. ENERGY PERFORMANCE INDEX (EPI)	11
VI. CARBON FOOT PRINT	12
INTRODUCTION	13
I. ENERGY AUDIT	13
II. COCHIN UNIVERSITY OF SCIENCE & TECHNOLOGY	14
III. GENERAL DETAILS	16
IV. LOAD BALANCE- ELECTRICAL	17
ENERGY & UTILITY DESCRIPTION	19
I. SINGLE LINE DIAGRAM – ELECTRICAL	19
ENERGY ANALYSIS	20
ELECTRICITY CONSUMPTION ANALYSIS	20
I. DESCRIPTION OF ELECTRICITY BILL	20
II. DEMAND ANALYSIS	22
III. ELECTRICITY DEMAND IN VARIOUS TIME ZONES	23
IV. POWER FACTOR ANALYSIS IN KSEBL BILL	24
V. TARIFF RATES ANALYSIS	25
UNINTERRUPTIBLE POWER SUPPLY (UPS)	26
ELECTRICITY SUPPLY & DISTRIBUTION PERFORMANCE	29
MAIN LOGGING – TRANSFORMER- MEASUREMENT EVALUATION	29
INFERENCE & OBSERVATION – TRANSFORMER EVALUATION	31
HARMONICS ASSESSMENT – AT TRANSFORMER SECONDARY	32
INFERENCE & OBSERVATION – HARMONIC ASSESSMENT	34
REACTIVE POWER COMPENSATION - ANALYSIS	35
BUILDING WISE LOAD & ENERGY - ANALYSIS	36
DIESEL GENERATOR	37
ANNEXURE – 1	38
ENERGY SAVING PROPOSALS - 1	38
ENERGY SAVING PROPOSALS - 2	40
ENERGY SAVING PROPOSALS - 3	41
ENERGY SAVING PROPOSALS - 4	45
ANNEXURE-2	47
CONNECTED LOAD	47



ANNEXURE-3	85
LIST OF INSTRUMENTS	85
IIABBREVIATIONS	85
REFERENCES:	85
CERTIFICATES	86



LIST OF TABLES

<i>TABLE 1: ENERGY SAVING PROPOSALS.....</i>	<i>8</i>
<i>TABLE 2: ANNUAL ENERGY CONSUMPTION.....</i>	<i>9</i>
<i>TABLE 3: ANNUAL ENERGY COST</i>	<i>9</i>
<i>TABLE 4: ENERGY PERFORMANCE INDEX.....</i>	<i>11</i>
<i>TABLE 5 CARBON FOOT PRINT</i>	<i>12</i>
<i>TABLE 6: GENERAL DETAILS.....</i>	<i>16</i>
<i>TABLE 7: LOAD BALANCE</i>	<i>17</i>
<i>TABLE 8: KSEBL BILL ANALYSIS.....</i>	<i>20</i>
<i>TABLE 9: UPS DETAILS.....</i>	<i>26</i>
<i>TABLE 10: TRANSFORMERS LOGGING.....</i>	<i>29</i>
<i>TABLE 11: TRANSFORMER ANALYSIS – INFERENCE & OBSERVATION.....</i>	<i>31</i>
<i>TABLE 12: HARMONICS CLASSIFICATION</i>	<i>32</i>
<i>TABLE 13: EFFECTS OF HARMONICS (IEEE 519).....</i>	<i>32</i>
<i>TABLE 14: CURRENT HARMONICS LIMIT (IEEE 519-2014).....</i>	<i>33</i>
<i>TABLE 15: VOLTAGE HARMONICS LIMIT (IEEE 519-2014).....</i>	<i>33</i>
<i>TABLE 16: TOTAL HARMONIC DISTORTION AT THE TRANSFORMER SECONDARY.....</i>	<i>33</i>
<i>TABLE 17: INFERENCE & OBSERVATION – HARMONIC ASSESSMENT</i>	<i>34</i>
<i>TABLE 18: CAPACITOR DETAILS.....</i>	<i>35</i>
<i>TABLE 19: BUILINGWISE LOAD ANALYSIS</i>	<i>36</i>
<i>TABLE 20 DG DETAILS.....</i>	<i>37</i>
<i>TABLE 21: EC PROPOSAL 1</i>	<i>39</i>
<i>Table 22: EC PROPOSAL 2</i>	<i>40</i>
<i>TABLE 23: EC PROPOSAL 3.....</i>	<i>45</i>
<i>TABLE 24: EC PROPOSAL 4.....</i>	<i>46</i>



LIST OF FIGURES

FIGURE 1: CAMPUS LAYOUT 15

FIGURE 2: LOAD BALANCE – ELECTRICAL 18

FIGURE 3: SINGLE LINE DIAGRAM – ELECTRICAL..... 19

FIGURE 4: DEMAND IN VARIOUS TIME ZONE..... 22

FIGURE 5: ELECTRICITY DEMAND IN VARIOUS TIME ZONE 23

FIGURE 6: POWER FACTOR ANALYSIS 24

FIGURE 7: TARIFF RATE ANALYSIS 25



PREFACE

Every institution should be imparting knowledge about the campus environment and its surroundings through activities that follows the principles of sustainability. An energy audit is essential first step to reduce energy cost and greenhouse emissions. Audit is defined as a systematic and implement examination of data statements, records, operations and performance of an enterprise for a purpose. Energy audits is a systematic study or survey to identify how energy being used in its own facility. And identifying the energy savings opportunities in the building Behavioural Change through the student education can provide greatest benefit at least cost. Even small savings in each house holds make dramatic change in the society and for nation. The idea of energy conservation and sustainability will be percolated to society through students will have long standing effect and successful too.

This report is compiled by the BEE certified energy auditor along with the project engineers who are experienced in the field of energy, environment and management.



ACKNOWLEDGEMENTS

We express our sincere gratitude to Cochin University of Science and Technology for giving us an opportunity to carry out the project of Energy Audit. We are extremely thankful to management and all the staffs for their support to carry out the studies and for input data, and measurements related to the project of Energy Audit.

Also mentioning our Energy audit team members for successfully completing the assignment in time and making their best efforts to add value.

ENERGY AUDIT TEAM

1. **Mr. Santhosh A**
Registered Energy Auditor of Bureau of Energy Efficiency (BEE – Govt. of India)
Accredited Energy Auditor No – EA 7597
2. **Mr. Jaideep P P**
Senior Project engineer
3. **Mr. Harikrishnan**
Project engineer
4. **Ms. Keerthana K**
Project engineer

Yours faithfully

Managing Director
Athul Energy Consultants Pvt Ltd

EXECUTIVE SUMMARY

I. ENERGY SAVING PROPOSALS

TABLE 1: ENERGY SAVING PROPOSALS

Sl.	Energy conservation measures	Annual Energy Savings	Annual Financial Savings	Investment	Simple payback period
		kWh	Rs	Rs	Months
1	Power factor Improvement in electrical system	-	4,81,487	1,00,000	02
2	Replacement of fluorescent light fittings with LED lights	12,499	1,05,618	1,44,000	16
3	Replacement of Low -star rated AC's with 5 star rated AC's	76978	6,50,333	17,88,000	33
4	Replacement of Ceiling fans(60W) with BLDC fans 5 star rated(28W) – 350 nos	20,832	1,76,030	12,25,000	84
Total Savings		110309	1413468	3257000	28



II. PRESENT ANNUAL ENERGY CONSUMPTION

The present annual energy consumption has been analysed in table below with the available data from the college for the period Dec 2021 to Nov 2022.

TABLE 2: ANNUAL ENERGY CONSUMPTION

Particulars	Unit	Quantity	Gross calorific value (kCal)	Million kCal (Toe)
Electricity (KSEBL)	kWh	3192540	860	274.56

III. PRESENT ANNUAL ENERGY COST

Annual cost for energy consumption for the period Dec 2021 to Nov 2022.

TABLE 3: ANNUAL ENERGY COST

Particulars	Unit	Quantity	Average Cost/unit	Average Cost in Lakhs (Rs)
Electricity (KSEBL)	kWh	3192540	8.45	269.77

IV. ENERGY AUDIT SUMMARY & RECOMMENDATIONS

The summary of the report with respect to each section is as follows.

1. Baseline energy performance:

Electricity consumption analysis

- **Demand analysis:** The recorded maximum demand was found to be 1042 kVA which is 115.78% of the contract demand. RMD came as more than contract demand in 5 months for last year. Excess demand charges are also coming in that periods.
- **Power factor:** The PF varies from 0.96 to 0.99 during Dec 2021 to Nov 2022.
- **Sub-metering:** Sub metering of water in the major usage areas are to be provided for better control. Also records shall be kept for all the sub meter to under stand the variation in the consumption pattern in each section.
- **Modification in water distribution system:** Utilization of the terrain benefit for rain water collection in roofs of the buildings and thereby the provision for effective usage of the water. Use advanced taps in wash basins in canteen, kitchen etc. for reducing and controlling water usage.
Change in flesh system in departments (Dual flesh) for reduction in water consumption.
Around 30 KL of treated water is not using in the college.
- **Ceiling fan loads:** Ceiling fans are installed in majority of the areas by replacing it with Brushless DC fans which consumes in the range of 25 to 30W at full speed, instead of 60 -70W in normal fans, will reduce the power consumption considerably. Also, while purchasing new fans priority should be given for BLDC
- **AC loads:** Replace the continuously working AC's with 5 star rated AC. Setting temperature of the AC's should be 24-25°C.
- **Light Loads:** Replace the fluorescent tubes with LED lights. Motion sensors should be provided for the toilets.

2. Behavioral Changes

- Use of student volunteers for reducing electricity consumption in college
- Encourage student projects in connection with energy conservation areas such as in renewable energy area, use of terrain advantage of college buildings, automatic system for control the light, fan and air conditioning requirements
- Proper recording of log books, consumption of fuel (Electricity, LPG) to be maintained by facility manager. Along with this a facility management to be formed and the committee headed by Principal or any deputed person and the committee members include the persons from academics, students, PTA, Administration and facility engineer for verification



V. ENERGY PERFORMANCE INDEX (EPI)

EPI was based on the energy consumption in Dec 2021 - Nov 2022. The projected energy consumption after the implementation of energy saving proposals is given in the table below.

TABLE 4: ENERGY PERFORMANCE INDEX

Sl. No:	Energy Performance and climate impact	Unit	Baseline	Projection	Savings (%)
1	Annual Electricity Consumption	kWh	3192540	3082231	3.46
2	Annual Electricity Consumption	TOE	274.56	265.07	3.46
3	Annual Energy Cost	Rs in lakhs	314.02	305.59	2.68
4	Annual Carbon Footprint- Electricity	Ton CO ₂	2522.11	2434.96	3.46

Note: Unit conversions:

TOE = 10 million *kCal* (BEE energy audit manual)

MWh of electricity = 0.79 Ton of CO₂ (www.cea.gov.in)

Ton of LPG = 2.99 Ton of CO₂ (www.cea.gov.in)

Ton of Diesel = 2.4 Ton of CO₂ (www.cea.gov.in)

Ton of Wood = 1.54 Ton of CO₂ (www.cea.gov.in)

kWh of electricity = 860 *kCal* (BEE energy audit manual)

Kilogram of LPG = 10500 *kCal* (BEE energy audit manual)

Liters of Diesel = 9500 *kCal* (BEE energy audit manual)



VI. CARBON FOOT PRINT

Carbon footprint often used as short hand for carbon emission (usually in Tones) being emitted by an activity or by institution; this is an important component in ecological footprint or the depicting the biological space reduction in the earth. Various environment protection and energy conservation connected with carbon footprint. Institution took its accountability to protect nature and taken few steps for the carbon neutral campus.

TABLE 5 CARBON FOOT PRINT

Particulars	Energy consumption reduction (kWh)	Carbon Emission reduction (Ton CO ₂)	% of total
Replacement of 3000 nos : T8 tubes with 18W LED tube	90,720	63.50	96.89
Replacement of 28 nos : Ceiling fans with 30W BLDC fans	1,411	0.99	1.51
By using natural light ingression into the class rooms	1,000	0.70	1.07
Natural ventilation in the class rooms reduces the usage of fans	5,00	0.35	0.53
Total	93,631	66	100

INTRODUCTION

I. ENERGY AUDIT

An energy audit is a key to assessing the energy performance of an energy consuming facility and for developing an energy management program. The typical steps of an energy audit are:

- Preparation and planning
- Data collection and review
- Plant surveys and system measurements
- Observation and review of operating practices
- Data documentation and analysis
- Reporting of the results and recommendations

1.1. Definition of energy auditing

In the Indian Energy Conservation Act of 2001 (**BEE 2008**), an energy audit is defined as: "**The verification, monitoring and analysis of the use of energy and submission of technical report containing recommendations for improving energy efficiency with cost-benefit analysis and an action plan to reduce energy consumption.**"

1.2. Objectives of Energy Auditing

The objectives of an energy audit can vary from one plant to another. However, an energy audit is usually conducted to understand how energy issued within the plant and to find opportunities for improvement and energy saving. Sometimes, energy audits are conducted to evaluate the effectiveness of an energy efficiency project or program. In Cusat as per the request from the institution, we have assessed the energy consumption and saving opportunities at present scenario.

Methodology for the study

The methodology adopted for energy audit starts from historical energy data analysis, power quality analysis, monitoring of operational practices, system evaluation, cost benefit analysis of the energy conservation opportunities, and prepare plan for implementation. The proposals given in the report includes economical energy efficiency measures to reduce facilities unnecessary energy consumption and cost. The energy conservation options, recommendations and cost benefit ratio, indicating payback period are included in this report.

Scope of Work

The Scope of Work includes:

1. Historical energy data analysis.
2. Electrical, Mechanical and Thermal energy analysis.
3. Power Quality Analysis.
4. Identification of Energy saving opportunities.
5. Cost Benefit Analysis.

II. COCHIN UNIVERSITY OF SCIENCE & TECHNOLOGY

Cochin University of Science and Technology (CUSAT) was initially constituted as the University of Cochin through an Act of Kerala Government on 10th July 1971. The University of Cochin was re-constituted as Cochin University of Science and Technology (CUSAT) in February 1986, redefining its objectives as "promoting Graduate and Post-Graduate studies and Advanced Research in Applied Sciences, Technology, Industry, Commerce, Management and Social Sciences." CUSAT is now a world-ranking university with the specific purpose of developing higher education, emphasizing post-graduate studies and research in applied science, technology, industry, humanities, and commerce. CUSAT has consecutively been figured in the Times Higher Education World Ranking since 2017. The Times ranks around 1500 best universities worldwide annually with around 60 universities from India out of 967. CUSAT has also found a place in the QS World University Ranking and the National Institutional Ranking Framework (NIRF) of the India Government.

Cast in the mold of a federal University, CUSAT is now a premier Science and Technology University in the country, re-accredited with NAAC 'A' Grade. During the intervening four and half decades, CUSAT has made quantum leaps in its academic pursuits and has spread its wings far and wide, encompassing the novel and emerging realms of the horizon of knowledge. The University has entered into several collaborative ventures with reputed Universities and Institutions worldwide. Scores of National and International academic discourses, seminars, workshops, etc., are held in the University every year, providing opportunities to the student community to update themselves in their respective fields of study. The Advanced Centre for Atmospheric Radar Research (ACARR), one among the many Centres of excellence of CUSAT, is included in the Prime Minister's "Make in India Program." UGC/AICTE approves all the Academic Programmes of CUSAT. With the active support of the Government of Kerala and various Central agencies and international collaborations, the University is poised to scale new heights in the years to come. The research activities are supported and funded by the Central Government agencies like UGC, DST, DBT, MHRD, etc., as well as by various international research partners through various MoUs.

True to Kerala's legacy of being the friendliest state with an avowed dedication to education, CUSAT is home for students from across the globe. The University takes pride in the fact that it has an enviable record in campus recruitments. The pool of its highly successful and talented alumni, who adorn vital positions in several highly acclaimed R & D institutions and corporates in India and abroad, are the living testimony of the academic excellence of CUSAT.

VISION

The university aims to become an institution of global standard by continuously improving its quality of academic activities, taking up research and innovation in the frontier areas by ensuring conductive state –of –the –art infrastructure facilities.

MISSION

CUSAT will continuously strive to generate a human resource of global competence by imparting most modern knowledge and training to its student community and to take up Research and Development activities in the frontier areas so as to contribute positively to the progress of the society and the Nation. The University shall have the following objectives as its mission:

1. to encourage and promote research and innovation in applied science, technology, industry, commerce, management and social science for the advancement of knowledge and for the betterment of society;
2. to provide facilities and offer opportunities for graduate and post-graduate education in applied science, technology, industry, commerce, management and social science by instruction, training, research, development, innovation and extension and by such other means as the University may deem fit;
3. to devise and implement programmes of education in applied science, technology, industry, commerce, management and social science that are relevant to the changing needs of society, in terms of breadth of diversity and depth of specialization;
4. to serve as a centre for fostering co-operation and exchange of ideas between the academic and research community on the one hand and industry on the other;
5. to organize exchange programmes with other institutions of repute in India and abroad with a view to keeping abreast of the latest innovation and developments in relevant areas of teaching and research.




FIGURE 1: CAMPUS LAYOUT



III. GENERAL DETAILS

The general details of the Campus are given below in table.

TABLE 6: GENERAL DETAILS

Sl. No:	Particulars	Details
1	Name of the College	Cochin university of Science & Technology
2	Address	Cochin university of Science & Technology Kalamassery, Ernakulam 682022
3	Web site	Cusat.ac.in
4	Type of Building	Educational Institution
5	Annual Working Days	210
6	No: of Shifts	Day Shift (One) (9:00 AM -5:00 PM)
7	Average power consumption per month. (kWh/month)	266045
8	Average electricity charges per month. (Rs. /month)	2616860

**IV. LOAD BALANCE- ELECTRICAL**

The details of the loads in the campus at the audit time are given below:

TABLE 7: LOAD BALANCE

SI No:	Building Name	Connected Load in KW
1	Post Office	3.36
2	Hindi and Foreign language	72.5
3	Basketball court	1.5
4	Thriveni Coffee house	11.024
5	State bank of India	33.19
6	Savana Teachers Hostel Library	37.055
7	Hostel Sanathana	14.05
8	University Guest House	101.355
9	Bachelors Hostel	4.066
10	Gymnasium For men	4.066
11	Play school	4.066
12	Kunjali Marakar School of Engineering	383.25
13	Department of Physics	176.5
14	Substation	0.4
15	Dept. of Applied Chemistry	101.39
16	Dept. of Instrumentation	53.81
17	Dept. of Applied Economics	67.79
18	Dept. of Management Studies	64.13
19	Department of Mathematics	15.5
20	Observatory	7.58
21	Dept. of Statistics	88.5+30kVA
22	School of legal studies	86.06
23	Instrumentation block (Extension)	30.14
24	International Students Hostel	27.6
25	Bio Technology	148.505
26	Ship Technology	77.705
27	Ship Technology	36.38
28	School of environmental studies	203.283
29	Sarovar Hostel	21.355
30	Siberia Hostel	24.6
31	Pump House 1	10



32	Centre for science in Society	47.988
33	Centre for Budget Studies	15
34	Dept. of Polymer science	30
35	Administrative Building	51
36	Engineering Dept.	4.06
Total kW		2070.26




FIGURE 2: LOAD BALANCE - ELECTRICAL

ENERGY & UTILITY DESCRIPTION

In this section the single line diagram of electricity which provides an overview of the energy flow in the building.

I. SINGLE LINE DIAGRAM - ELECTRICAL

The electrical single line diagram of the college is given below:




FIGURE 3: SINGLE LINE DIAGRAM - ELECTRICAL



ENERGY ANALYSIS

The different type's energy usage is given in this section. The major source of energy to the college is electricity. Other forms come in the form of diesel.

ELECTRICITY CONSUMPTION ANALYSIS

The major source of electricity to the college is the electrical connection from the KSEBL. Diesel generators are provided in the college, but it is only used during the power failures in critical days like examinations or college events.

I. DESCRIPTION OF ELECTRICITY BILL

Base line data given below is based on the Electricity bill provided by the supplier of electricity to the College. Details obtained from the KSEBL bill for the month of Dec 2021-Nov 2022 is as follows in the Table.

TABLE 8: KSEBL BILL ANALYSIS

Particulars		Details
Consumer No		1356550000483
Contract Demand (kVA)		900
Connected Load (kW)		2959
Tariff		HT II (B) General
Recorded maximum demand (kVA)		1042 (Apr 22)
Average monthly electricity consumption (kWh/month)		2,66,045
Average Power factor		0.97
Average Demand charges (Rs/month)		4,12,901/-
Annual power factor penalty & Incentive (Rs/year)		Incentive - 2,90,285/-
Demand charge (Rs / kVA)		500
Energy charge (Rs/kWh)	Normal Period	7.8
	Peak Period	11.7
	Off - Peak Period	5.85
Average electricity cost (Rs/month)		26,16,860/-



Inference & Suggestions

- Average Power factor is found to be 0.97. Getting incentives every month for maintaining the power factor.
- For last 12 months, there is only in one month getting the incentive.
- Excess demand charges came 5 months in last year.
- By maintaining the power factor near unity, without leading power factor the college will get incentives for the power factor.
- Recorded maximum demand (RMD) during past 12 month was 1042 kVA. It was recorded during the month of Apr 2022, which is 115.78% of contract demand.
- By analysing the RMD for past year it is clear that by maintain the power factor to unity will reduce the demand charges and the incentive amounts will be more.



II. DEMAND ANALYSIS

This section analyses the trend for the maximum demand versus the Contract Demand (CD) over a 12-month period (Dec 2021-Nov 2022).




FIGURE 4: DEMAND IN VARIOUS TIME ZONE

Inference

- i. Annual demand charges came as Rs. 49,54,817 /- for the campus.
- ii. The recorded maximum demand was found to be 1042 kVA which is 115.78% of the contract demand.
- iii. RMD came as more than contract demand in 5 months for last year. Excess demand charges are also coming in that periods.

Suggestion

- i. Maintaining the power factor to near unity will reduce the RMD.

III. ELECTRICITY DEMAND IN VARIOUS TIME ZONES

The variations of demands in the time zones are given below in figure.




FIGURE 5: ELECTRICITY DEMAND IN VARIOUS TIME ZONE

Inference

- i. The average demand registered during the normal, Peak and off-peak period with respect to the contract demand (900 kVA) were 96.67%, 54.53% and 39.19% respectively.
- ii. The maximum demand registered during the normal, Peak and off-peak period with respect to the contract demand (900 kVA) were 115.78%, 72.67% and 47.56% respectively.

IV. POWER FACTOR ANALYSIS IN KSEBL BILL

The Power factor is the ratio of Active power (kW) and apparent power (kVA).

$$PF = \frac{\text{Active energy}(kWh)}{\text{Apparent energy}(kVAh)}$$

The power factor variations in past one year is given below in figure.




FIGURE 6: POWER FACTOR ANALYSIS

Inference

- i. The PF varies from 0.96 to 0.99 during Dec 2021 to Nov 2022.
- ii. Average power factor during the past one year is found to be 0.97.

Suggestion

- i. Replace the faulty capacitors from the APFC panel.
- ii. Provide small divisions of capacitors (1, 2 kVAr) to the MSB for maintain the pf in low load conditions.

V. TARIFF RATES ANALYSIS

The average monthly energy and demand charges for the period Dec 2021-Nov 2022 is represented in Fig.




FIGURE 7: TARIFF RATE ANALYSIS

Inference

- i. Average demand charges for the past one year were Rs 4,12,901/-per month and energy charges was Rs. 20,19,543/- per month.
- ii. The energy charges come about 76% of the total bill for the campus.

UNINTERRUPTIBLE POWER SUPPLY (UPS)

TABLE 9: UPS DETAILS

Location	UPS		Battery			Year
	Capacity kVA	Name	Rating V, Ah	Quantity Nos	Make	
Applied Electronics - First Floor	10	Igatech	12, 75	18	Exide	
SMS - Ground Floor	15	Suntroani	12, 150	10	Exide	
SMS - Ground Floor	15		12, 200	10	Exide	
Inverter	2.5	Hykon	12, 150	2	Hykon	
SMS - First Floor	10	Hykon	12, 150	20	Hykon	
DDUK - First Floor	20	Hykon	12, 120	40	Hykon	
Mathematics -Ground Floor	1.5	Keptron	12, 150	2	Supra	
Mathematics -First Floor	1.5	Keptron	12, 150	2	Supra	
Mathematics -Second Floor	10	Supra	12, 26	16	Quanta	
Central Library - New Block	40	Igatech	12, 100	50	Rocket	
Central Library - Old Block	20	Hykon	12,100	30	Rocket	
Chemistry Dept	5	Supra	12,75	16	Exide	2011
Chemistry Dept	5	Supra	12,75	16	Exide	
Insta Lab	20	Supra	12,100	16	Hipower	
Insta Lab	10	Rocket	12,75	20	Hipower	
Near Recreation	2	IWN	12,75	4	Exide	2016
Near Recreation	2	Techsar	12,75	8	Exide	2016
Near Recreation	3	Zenster	12,75	8	Exide	2021
Near Recreation	3	Zenster	12,75	8	Exide	2021
Physics (TFD)	15	Techsar	12,75	20	Rocket	2020
Nuclear Lab (Physics Dept)	6	Delta	12,65	16	Exide	
Dr. Jayasree Room near	2	Hykon	12,65	4	Exide	2017
Dr. Jayasree Room near	6	Delta	12,88	16	Exide	
XRD	5	Techsar	12,40	10	Rocket	
Computer	5	Zenster	12,120	10	Zenster	2018

Nanophotonics	5	Techsar	12,42	10	Exide	2020
Nanophotonics	15	Techsar	12,42	20	Exide	2021
Nanophotonics	5	Techsar	12,42	10	Exide	2020
Nanophotonics	3	Techsar	12,42	8	Exide	2022
Nanophotonics	15	Techsar	12,75	30	Exide	2018
Cosmology	3	Zenster	12,16	6	Zenster	
SBI	5	Numeric	12,150	10	Hipower	2009
SBI	3	Numeric	12,40	6	Exide	2010
Common Facility	1.5	Emerge	12,150	6	Exide	
Biotech (Near Microbial Genetics)	6	APC	12,100	16	Exide	
Biotech (Near Microbial Genetics)	6	APC	12,75	16	Luminous	
SLS - Ground Floor	5	Hykon	12,100	10	Hykon	
Dept of English & SL	1.5		12,150	4	Exide	
Dept of English & SL	5.5		12,150	4		
Dept of English & SL	10	Hykon	12,150	20	Hykon	
Photonics	20	Techsar	12,100	20	Techsar	
Photonics	20	Techsar	12,100	20	Techsar	
Photonics	3	Zenster	12,100	8		
Ship Technology	10		12,75	18	Exide	
Dept of Polymer Science	3	Igatech		4	Amaron	
Dept of Polymer Science	3	Igatech	12,100	4	Amaron	
Dept of Polymer Science	10		12,100	3	Amaron	
Dept of Polymer Science	20		12,100		Powersafe	
Dept of Polymer Science	3					
Admin block	40	Igatech	12,100	42	Hipower	
Second floor	60	Supra		48	Exide	
Marine block						
Lab 108	10	Hykon		20		

Suggestions

- i. Proper ventilation should be provided for UPS and batteries.
- ii. UPS room should be kept neat and clean.
- iii. Petroleum jelly should be applied to the battery terminals for better life.

ELECTRICITY SUPPLY & DISTRIBUTION PERFORMANCE

The objective of this section is to establish how the facility is performing in terms of energy consumption.

MAIN LOGGING - TRANSFORMER- MEASUREMENT EVALUATION

The main logging of transformers conducted using the Krykard power quality analyser. The Secondary side of the transformers was logged for 24 hours and measured data is given in following table. The measurement-averaging period was 02 minutes.

The summary of measured parameters of the transformer is given in the table below.

TABLE 10: TRANSFORMERS LOGGING

Particulars		TR 1	TR 2
Rating (kVA)		500	500
Voltage ratings (kV)		11/0.433	11/0.433
Current ratings (A)		26.24/666.5	26.24/666.5
Volt impedance - %		5.17	5.21
Year		2008	2008
Parameters		TR 1	TR 2
Voltage line (V)	Min	398	399
	Avg	403.49	404.45
	Max	412.1	411.25
Current (A)	Min	119.3	95.26
	Avg	173.49	75.26
	Max	220.3	101.56
Frequency (Hz)	Min	49.83	49.81
	Avg	49.97	49.99
	Max	50.2	50.3
Energy consumed (kWh)	Total	2800	1500
Energy received (kVAh)	Total	2828	1531
Power factor		0.99	0.98
Active power (kW)	Min	108.65	101.55
	Avg	120.97	115.52
	Max	135.31	125.65
Apparent power (kVA)	Min	108.89	102.5
	Avg	121.31	116.5
	Max	135.69	127.56
Reactive power (kVAR)	Min	0.12	1.52
	Avg	4.94	5.66
	Max	10.64	11.65
Voltage imbalance %	Min	0.1	0.2
	Avg	0.25	0.35
	Max	0.4	0.5



Parameters		TR 1	TR 2
Current imbalance %	Min	10.4	11.65
	Avg	17.83	18.95
	Max	30.4	32.56
THDv %	Min	0.8	1.1
	Avg	1.15	1.58
	Max	1.7	2.1
THDa %	Min	3.2	3.6
	Avg	4.55	4.25
	Max	8	8.25

**INFERENCE & OBSERVATION – TRANSFORMER EVALUATION****TABLE 11: TRANSFORMER ANALYSIS – INFERENCE & OBSERVATION**

TRANSFORMER - ANALYSIS											
Inference		Observation									
<ul style="list-style-type: none"> The maximum and average loading of each transformer during the period of audit is: <table border="1"> <thead> <tr> <th></th> <th>Max load %</th> <th>Avg load %</th> </tr> </thead> <tbody> <tr> <td>TR 1 (500 kVA)</td> <td>27.14</td> <td>24.26</td> </tr> <tr> <td>TR 2 (500 kVA)</td> <td>23.30</td> <td>25.51</td> </tr> </tbody> </table>			Max load %	Avg load %	TR 1 (500 kVA)	27.14	24.26	TR 2 (500 kVA)	23.30	25.51	<ul style="list-style-type: none"> The present loading pattern of the transformer is not good.
	Max load %	Avg load %									
TR 1 (500 kVA)	27.14	24.26									
TR 2 (500 kVA)	23.30	25.51									
<ul style="list-style-type: none"> The load factor $[(\text{Load factor (\%)} = \text{Energy used during the period (kWh)} \times 100 \div \{\text{Maximum demand (kW)} \times \text{Time under consideration (hr)}\})]$ of the transformer during the audit period is: <table border="1"> <thead> <tr> <th></th> <th>Load factor %</th> </tr> </thead> <tbody> <tr> <td>TR 1 (500 kVA)</td> <td>68.56</td> </tr> <tr> <td>TR 2 (500 kVA)</td> <td>65.58</td> </tr> </tbody> </table>			Load factor %	TR 1 (500 kVA)	68.56	TR 2 (500 kVA)	65.58	<ul style="list-style-type: none"> Load factor of transformer is not good 			
	Load factor %										
TR 1 (500 kVA)	68.56										
TR 2 (500 kVA)	65.58										
<ul style="list-style-type: none"> The power factor variations among the transformer are tabulated below; <table border="1"> <thead> <tr> <th></th> <th>PF - Avg</th> </tr> </thead> <tbody> <tr> <td>TR 1 (500 kVA)</td> <td>0.99</td> </tr> <tr> <td>TR 2 (500 kVA)</td> <td>0.98</td> </tr> </tbody> </table>			PF - Avg	TR 1 (500 kVA)	0.99	TR 2 (500 kVA)	0.98	<ul style="list-style-type: none"> The present PF in the college is found to be low at the time of audit and leading occurs. PF should be improved to unity to receive incentives. 			
	PF - Avg										
TR 1 (500 kVA)	0.99										
TR 2 (500 kVA)	0.98										

HARMONICS ASSESSMENT – AT TRANSFORMER SECONDARY

Harmonics study revolves around the use of non-linear loads that are connected to electric power systems including static power converters, arc discharge devices, saturated magnetic devices and to a lesser degree, rotating machines. Static power converters of electric power are the largest non-linear loads and are used in industry for a variety of purposes such as electro- chemical power supplies, adjustable speed drives, and uninterruptible power supplies. These devices are useful because they can convert ac to dc, dc to dc, dc to ac, and ac to ac. Non-linear loads change the sinusoidal (a succession of waves or curves) nature of the ac power current (and consequently the ac voltage drop) thereby resulting in the flow of harmonic currents in the ac power system that can cause interference with communication circuits and other types of equipment. Classification, effects and standards are given below:

TABLE 12: HARMONICS CLASSIFICATION

	1st order	2nd order	3rd order	3rd order	4th order	5th order	6th order
Frequency Hz	50	100	150	200	250	300	350
Sequence	+	-	0	+	-	0	+

TABLE 13: EFFECTS OF HARMONICS (IEEE 519)

Effect on - Motor & generator	-Transformers	- Cables	- Electronic equipment	- Metering
Rotor heating, causes Reverse rotating magnetic field, causes pulsating torque output, Mechanical oscillations, increases Cogging & Crawling	Increase in copper & stray losses, increase in iron losses, transformer heating	Voltage stress & corona, I ² R losses increases	Voltage notching, Electromagnetic interference, Shifting of the voltage zero crossing	Erroneous reading



TABLE 14: CURRENT HARMONICS LIMIT (IEEE 519-2014)

Maximum harmonic current distortion in percent of I_L						
Individual harmonic order (odd harmonics) ^{a, b}						
I_{sc}/I_L	$3 \leq h < 11$	$11 \leq h < 17$	$17 \leq h < 23$	$23 \leq h < 35$	$35 \leq h \leq 50$	TDD
$< 20^c$	4.0	2.0	1.5	0.6	0.3	5.0
$20 < 50$	7.0	3.5	2.5	1.0	0.5	8.0
$50 < 100$	10.0	4.5	4.0	1.5	0.7	12.0
$100 < 1000$	12.0	5.5	5.0	2.0	1.0	15.0
> 1000	15.0	7.0	6.0	2.5	1.4	20.0

^aEven harmonics are limited to 25% of the odd harmonic limits above.

^bCurrent distortions that result in a dc offset, e.g., half-wave converters, are not allowed.

^cAll power generation equipment is limited to these values of current distortion, regardless of actual I_{sc}/I_L .

where

I_{sc} = maximum short-circuit current at PCC

I_L = maximum demand load current (fundamental frequency component)
at the PCC under normal load operating conditions

TABLE 15: VOLTAGE HARMONICS LIMIT (IEEE 519-2014)

Voltage distortion limits		
Bus voltage at PCC	Individual voltage distortion %	Total voltage harmonics distortion %
$V \leq 01 \text{ kV}$	5.0	8.0
$01 \text{ kV} < V \leq 69 \text{ kV}$	3.0	5.0
$69.001 \text{ kV} < V \leq 161 \text{ kV}$	1.5	2.5
161.001 kV and above	1.0	1.5

HARMONICS MEASUREMENT

1. Standard for harmonics - IEEE 519-2014
2. Normal range of I_{sc}/I_L in the plant - $20 < x \leq 50$
3. Maximum standard Total demand distortion - current - 5%
4. Maximum standard Total harmonic distortion - voltage - 5%

TABLE 16: TOTAL HARMONIC DISTORTION AT THE TRANSFORMER SECONDARY

Particulars	Rated power	THDv max	THDa max	Remarks	Status with IEEE 519-2014
	kVA	%	%		
Transformer 1	500	1.70	8	THDa is higher than the prescribed limit	High
Transformer 2	500	1.72	8.25	THDa is higher than the prescribed limit	High



Where:

- THDv – Total harmonic distortion voltage
- THDa – Total harmonic distortion current

INFERENCE & OBSERVATION – HARMONIC ASSESSMENT

TABLE 17: INFERENCE & OBSERVATION – HARMONIC ASSESSMENT

Harmonics	
Observation	Suggestion
<ul style="list-style-type: none">➤ The present THD current at the secondary side of the transformer is higher than the prescribed limit. (<5% shall be the current value).➤ The voltage THD is found to be within the limits of 5%.➤ When we analysed, the major cause for the effect of high THD current is the presence of UPS.	<ul style="list-style-type: none">➤ To reduce the harmonic effect in the system, the purchase tender of equipment such as UPS, VFD & LED shall contain the Harmonic limitation standard as per the IEEE 519.➤ This will reduce the effects of non-linear loads in the system.

REACTIVE POWER COMPENSATION - ANALYSIS

APFC panels are installed at the secondary side of the transformer. The rated details and performance of the installed units of capacitors is given below:

TABLE 18: CAPACITOR DETAILS

Name	Rated kVAr	Design Voltage	Measured Voltage	Measured kVAr	kVAr w.r.t to Volts	% of deterioration
	A	B	C	E	$F = E \cdot (B/C)^2$	$G = (A-F) \cdot (100/A)$
Stage 1	10	440	401.6	7.90	9.48	5.16
Stage 2	15	440	401.6	11.96	14.36	4.29
Stage 3	15	440	401.6	12.01	14.42	3.89
Stage 4	20	440	401.6	10.30	12.36	38.18
Stage 5	20	440	401.6	10.23	12.28	38.60
Stage 6	30	440	401.6	24.85	29.83	0.57
Stage 7	30	440	401.6	20.52	24.63	17.89
Stage 8	30	440	401.6	24.87	29.85	0.49

Inference

1. Some capacitors in the APFC panels are not working well.
2. Power factor can be improved to unity so as to increase the incentives received by the college.

Suggestion

1. Replace/Repair the faulty capacitors in the APFC panel.
2. Provide small rating capacitors to the APFC panel.

BUILDING WISE LOAD & ENERGY - ANALYSIS

At the time of audit, building wise load analysis was taken and logged details are tabulated below:

TABLE 19: BUILDINGWISE LOAD ANALYSIS

Sl.No:	Name	Voltage	Current	Measured Power			PF
		Volts	Amps	kW	kVA	kVAr	
1	AMF Admin	428	110.12	71.28	73.68	14.22	0.97
2	Budget Studies	429	18.15	9.40	10.48	2.59	0.89
3	Computer Centre	413	47.6	32.54	33.92	5.15	0.96
4	Electronics GF	432	49.2	27.02	29.8	8.89	0.91
5	Electronics Staircase	433	24.2	12.88	13.35	3.15	0.96
6	MCA	416	22.7	13.05	14.94	6.96	0.87
7	OH Line, Ladies Hostel, Library	417	66.7	48.45	50.54	12.17	0.96
8	Photonics	431	41.8	25.11	25.57	3.41	0.98
9	Pump House, Ship P SRT OH Line	417	71.14	50.21	51.34	1.98	0.98
10	SCS Top floor - Electronics	414	55.7	31.67	33.09	9.07	0.96
11	Biotechnology & B Tech Hostel	405	111.81	77.22	78.41	11.74	0.98
12	Guest House & Statistics	416	104.50	71.69	75.33	21.99	0.95
13	STP	416	9.98	5.61	7.21	4.41	0.76
14	Amenity Centre	416	15.35	9.76	11.03	-4.05	0.88
15	Kunjali Marakkar Block	404	59	38.25	41.35	15.43	0.92
16	Physics, Chemistry, Instrumentation & SLS	415	136.44	97.01	98.12	9.61	0.99

DIESEL GENERATOR

Diesel generator used in the campus as backup supply. There are DG's provided in the facility for different areas. The following table gives the basic details of diesel generator in the facility.

TABLE 20 DG DETAILS

Location	Capacity (kVA)	Make
SMS	150	Kirloskar
SLS	35	Mahindra
Dept. of Eng & SL	45	Kirloskar
Photonics	2.8	

Inference & Suggestions ❖ *The diesel consumption for DG is not recorded properly. A log book to monitor the diesel consumption(L) and unit consumption(kWh) shall be maintained and record it after its running.*

ANNEXURE - 1

ENERGY SAVING PROPOSALS - 1

PF IMPROVEMENT IN ELECTRICAL SYSTEM

Background

By referring the last year bills, it is clear that the average power factor was varying from 0.97 to 0.99.. Last 12 months here getting the incentives for power factor.

Proposal

Replace/Repairing the existing capacitors in APFC panels with a new one and also providing small rating capacitors from the MSB to improve the PF to unity and gain incentives. For improving the power factor to unity then the demand charges also will reduce. The calculations regarding the present scenario is tabulated below:

Present Condition - Contract Demand is 900 kVA and PF is 0.97					
Month	RMD	BD	PF	Demand Charges	Incentives
	KVA	KVA	Rs	Rs	Rs
Dec-21	771	675	0.97	339240	17955
Jan-22	755	675	0.96	332200	8349
Feb-22	744	675	0.96	327360	7765
Mar-22	979	675	0.97	448140	22391
Apr-22	1042	675	0.97	489720	22101
May-22	994	675	0.97	458040	21188
Jun-22	781	675	0.97	342617	18579
Jul-22	730	675	0.98	365000	28711
Aug-22	852	675	0.98	426000	30554
Sep-22	921	675	0.99	465750	40411
Oct-22	1001	675	0.98	525750	35935
Nov-22	870	675	0.98	435000	36345
SUM				4954817	290285

Proposed Condition - Contract Demand is 225 kVA and PF is 1							
<i>Month</i>	<i>RMD</i>	<i>BD</i>	<i>Demand Charges</i>	<i>Savings in Demand Charges</i>	<i>Incentives</i>	<i>Savings in Incentives</i>	<i>Total Savings</i>
	<i>KVA</i>		<i>Rs</i>	<i>Rs</i>	<i>Rs</i>	<i>Rs</i>	<i>Rs</i>
Dec-21	748	675	3,29,063	10,177	44,887	26,932	37,109
Jan-22	725	675	3,18,912	13,288	41,744	33,395	46,683
Feb-22	714	675	3,14,266	13,094	38,826	31,060	44,155
Mar-22	950	675	4,28,837	19,303	55,978	33,587	52,890
Apr-22	1011	675	4,69,146	20,574	55,252	33,151	53,726
May-22	964	675	4,24,239	33,801	52,970	31,782	65,583
Jun-22	758	675	3,33,331	9,286	46,448	27,869	37,155
Jul-22	715	675	3,57,700	7,300	47,852	19,141	26,441
Aug-22	835	675	4,17,480	8,520	50,923	20,369	28,889
Sep-22	912	675	4,58,895	6,855	50,514	10,103	16,958
Oct-22	981	675	5,10,740	15,010	59,892	23,957	38,967
Nov-22	853	675	4,26,300	8,700	60,577	24,232	32,932
SUM				47,88,908	1,65,909	6,05,863	3,15,578

Summary of the Proposal

TABLE 21: EC PROPOSAL 1

<i>Annual Incentive Increment</i>	<i>Rs</i>	<i>3,15,578</i>
<i>Annual Demand Charges Savings</i>	<i>Rs</i>	<i>1,65,909</i>
<i>Total Savings</i>	<i>Rs</i>	<i>4,81,487</i>
<i>Investment</i>	<i>Rs</i>	<i>1,00,000</i>
<i>Simple Payback Period</i>	<i>Months</i>	<i>02</i>

ENERGY SAVING PROPOSALS - 2

REPLACEMENT OF FLOURESCENT LIGHT FITTINGS WITH LED LIGHTS

The present light fittings are mainly being the fluorescent light of different ratings. By replacing these light fittings with LED, the consumption of electricity will reduce considerably.

Particulars	Units	T12	T8	T5
Power of Fluorescent lights	Watts	40	36	28
Power of proposed LED tube	Watts	20	20	20
Difference in Wattage	Watts	20	16	8
Avg No: of working hours/day	Hrs	8	8	8
No: of working days per year (Average)	Nos	210	210	210
No: of working hours per annum	Hrs	1680	1680	1680
Number of Lights operating	Nos	100	300	80
kWh Saving per Annum	Rs	3360	8064	1075.2
Cost per kWh (Average)	Rs	8.45	8.45	8.45
Annual Financial Savings	Rs	28392	68140.8	9085.44
Cost of LED tube	Rs	300	300	300
Investment for LED lights	Rs	30000	90000	24000
Simple Payback period	Months	13	16	32

Summary of the proposal

Table 22: EC PROPOSAL 2

Annual Unit Savings	kWh	12,499
Total Savings	Rs	1,05,618
Total Investment	Rs	1,44,000
Payback Period	months	16

ENERGY SAVING PROPOSALS - 3

REPLACEMENT OF LOW STAR RATED AC'S WITH 5 STAR RATED AC'S

Background

Here 1 TR, 1.5 TR and 2T low star rated ACs are provided in the labs and classrooms and office working 8 hours daily above 4 Years consumes higher power.

Proposal

Replace the AC with 5 star rated one will provide sufficient energy savings. The calculations are given below:

1. CAPACITY OF AIR CONDITIONER -1 TR

Particulars	Location	Department of Physics	Department of Physics	Department of Chemistry	Interuniversity	Department of Statistics
	Area	TFD	Magnetics	Instr. Room 1	Faculty post doc	Computer Lab
Present power consumption of AC	Watts	1040	1028	1230	1076	1094
Capacity of proposed 5 Star Inverter AC	TR	1	1	1	1	1
Power of proposed 5 Star Inverter AC	Watts	920	920	920	920	920
Difference in Wattage	Watts	120	108	310	156	174
Avg No: of working hours/day	Hrs	8	8	8	8	8
No: of working days per year	Nos	210	210	210	210	210
No: of working hours per annum	Hrs	1680	1680	1680	1680	1680
Total no:of AC's operating	Nos	1	1	1	1	2
Annual power consumption of old airconditioners	kWh	1747.2	1727.04	2066.4	1807.68	3675.84
No: of working hours of new AC	Hrs	4	4	4	4	4
Annual working hours of new AC	Hrs	840	840	840	840	840
Annual energy consumption of new AC	kWh	772.8	772.8	772.8	772.8	1545.6
kWh Saving per Annum	kWh	974	954	1,294	1,035	2,130
Cost per kWh (Average)	Rs	8.45	8.45	8.45	8.45	8.45
Annual Financial Savings	Rs	8,234	8,063	10,931	8,745	18,001
Investment for AC	Rs	32,000	38000	38000	38000	38000
Total Investment	Rs	32,000	38,000	38,000	38,000	76,000
Simple Payback period	Months	47	57	42	52	51
SUMMARY						
Annual unit savings	kWh	6387				
Total savings	Rs	53973				
Total investment	Rs	222000				
Payback period	months	49				



2. CAPACITY OF AIR CONDITIONER -1.5 TR

Particulars		Department of Physics				Department of Chemistry	Department of Biotechnology	SMS	Central Library	Old Building	SLS	Department of English & FL		Photronics	Ship Technology	SBI	Interuniversity
		Laboratory	Office	Nanophotonics		Instr. Lab 2	Nanobiotech	Hall of Fame	E Journals	Audio visual & research centre	Seminar Hall	Faculty room	Lab	Computer Lab	HOD	Bank Hall	Classroom, Chara. Lab 2
Present power consumption of AC	Watts	2300	1129	1842	1122	1362	1940	1728	1432	1586	1860	1428	1458	1882	1654	1544	1355
Capacity of proposed 5 Star Inverter AC	TR	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
Power of proposed 5 Star Inverter AC	Watts	1100	1100	1100	1100	1100	1100	1100	1100	1100	1100	1100	1100	1100	1100	1100	1100
Difference in Wattage	Watts	1200	29	742	22	262	840	628	332	486	760	328	358	782	554	444	255
Avg No: of working hours/day	Hrs	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
No: of working	Nos	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210



days per year																		
No: of working hours per annum	Hrs	1680	1680	1680	1680	1680	1680	1680	1680	1680	1680	1680	1680	1680	1680	1680	1680	1680
Total no:of AC's operating	Nos	2	2	2	1	1	1	4	3	4	1	1	1	1	1	1	1	3
Annual power consumption of old AC	kWh	7728	3793.44	6189.12	1885	2288.16	3259.2	11612.16	7217.28	10657.92	3124.8	2399.04	2449.44	3161.76	2778.72	2593.92	6829.2	
Working hours per day of new AC	Hrs	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
Annual power consumption of new AC	kWh	1848	1848	1848	924	924	924	3696	2772	3696	924	924	924	924	924	924	2772	
kWh Saving per Annum	kWh	5,880	1,945	4,341	961	1,364	2,335	7,916	4,445	6,962	2,201	1,475	1,525	2,238	1,855	1,670	4,057	
Cost per kWh (Average)	Rs	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	8.45	
Annual Financial Savings	Rs	49,686	16,439	36,682	8,120	11,527	19,732	66,892	37,563	58,828	18,597	12,464	12,890	18,909	15,672	14,111	34,283	



Investment for AC	Rs	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000	40,000
Total Investment	Rs	80,000	80,000	80,000	40,000	40,000	40,000	1,60,000	1,20,000	1,60,000	40,000	40,000	40,000	40,000	40,000	40,000	1,20,000
Simple Payback period	Months	19	58	26	59	42	24	29	38	33	26	39	37	25	31	34	42
Summary																	
Annual unit savings				kWh		51,171											
Total savings				Rs		4,32,396											
Total investment				Rs		11,60,000											
Payback period				months		32											

3. CAPACITY OF AIR CONDITIONER – 2 TR

Particulars		Library	Microbiology, Microbial	Library
Present power consumption of AC	Watts	2392	2218	2113
Capacity of proposed 5 Star Inverter AC	TR	2	2	2
Power of proposed 5 Star Inverter AC	Watts	1487	1487	1487
Difference in Wattage	Watts	905	731	626
Avg No: of working hours/day	Hrs	8	8	8
No: of working days per year	Nos	210	210	210
No: of working hours per annum	Hrs	1680	1680	1680
Total no:of AC's operating	Nos	1	3	4
Annual power consumption of old Acs	kWh	4018.56	11178.72	14199.36
Working houres per day of new Acs	Hrs	4	4	4
Annual energy consumption of New Acs	kWh	1249.08	3747.24	4996.32
kWh Saving per Annum	kWh	2,769	7,431	9,203
Cost per kWh (Average)	Rs	8.45	8.45	8.45
Annual Financial Savings	Rs	23,402	62,796	77,766
Investment for AC	Rs	50,000	50,000	50,000
Total Investment	Rs	50,000	1,50,000	2,00,000
Simple Payback period	Months	26	29	31
SUMMARY				
Annual unit savings	kWh	19,404		
Total savings	Rs	1,63,964		
Total investment	Rs	4,00,000		
Payback period	months	29		

TABLE 23: EC PROPOSAL 3

Particulars	Unit	Values		
Capacity of proposed 5 Star Inverter AC	TR	1	1.5	2
Total no:of AC's operating	Nos	6	29	8
Annual unit savings	kWh	6387	51,187	19,404
Net annual savings	Rs	53,973	4,32,396	1,63,964
Net annual investment for AC	Rs	2,28,000	11,60,000	4,00,000
Annual unit savings	kWh	76,978		
Total savings	Rs	6,50,333		
Total investment	Rs	17,88,000		
Payback period	months	33		

ENERGY SAVING PROPOSALS - 4

REPLACEMENT OF CEILING FANS IN THE OFFICE WITH ENERGY EFFICIENT BLDC FANS

BACKGROUND

A BLDC fan takes in AC voltage and internally converts it into DC using SMPS. The main difference between BLDC and ordinary DC fans is the commutation method. A commutation is basically the technique of changing the direction of current in the motor for the rotational movement. In a BLDC motor, as there are no brushes, so the commutation is done by the driving algorithm in the Electronics. The main advantage is that over a period, due to mechanical contact in a brushed motor the commutators can undergo wear and tear, this thing is eliminated in BLDC Motor making the motor more rugged for long-term use. To explain, BLDC technology in simpler terms, BLDC uses a combination of Permanent Magnets and Electronics to achieve the kind of efficiency and performance, it delivers. A BLDC fan composes of 3 main components: - 1. Stator 2. Rotor 3. Electronics

PROPOSAL

Replace the ceiling fans with BLDC in the as per preference of operating hours as office areas, staff rooms, hostel and in class rooms, the calculation for the savings is given in the table.

Particulars	Units	College	Hostels
Power of existing ceiling fans at full speed	Watts	60	60
Power of BLDC fans at full speed	Watts	28	28
Difference in Wattage	Watts	32	32
Avg No: of working hours/day	Hrs.	8	10
No: of working days per year (Average)	Days	210	210
Number of Ceiling Fans operating	Nos	200	150
kWh Saving per Annum	kWh/annum	10,752	10,080
Cost per kWh (Average)	Rs/kWh	8.45	8.45
Annual Financial Savings	Rs/annum	90,854	85,176
Cost of BLDC Fans	Rs/no	3,500	3,500
Investment for BLDC Fans	Rs	7,00,000	5,25,000
Simple Payback period	Months	92	74

Summary of the proposal

TABLE 24: EC PROPOSAL 4

Annual Unit Savings	kWh/annum	20,832
Total Savings	Rs/annum	176,030
Total Investment	Rs	1,225,000
Payback Period	Months	84

ANNEXURE -2

CONNECTED LOAD

I. LIGHT & FAN LOAD

Location	LED Tube									LED Tube	LED Square	LED	T5	T8	T12	T5 (2 Ft)	CFL				BL DC	Ceiling Fan		Table fan	Pedes. Fan	Ex. Fan		Wall Fan			
	18	4	5	6	8	9	12	18	150								36	40	500	28		36	40			14	10		11	18	24
Dept. of Applied Electronics																															
Corridor	2																														
Ground Floor																															
Corridor	5																														
Library	17											1	19	7								3	21								2
Toilets						8							2																		
SMS Library	37									4		6	21									6			4						4
Research Scholar	1													1								2									
Computer Lab	5											1										3									4
Seminar Hall	1	8											11																		9
First Floor																															
Corridor	3												1																		
HOD Room	1												1									2									
Room 13												1		2								3									
Corridor	6																														
Office (3 Rooms)	8													1								6			1						
Toilets	2					6																									
Classroom (9)	4											2										4									



Classrooms (12 Rooms)	8				12						4								12					
Faculty room	2										7								5			1		
Classrooms (S5, S4)					11														7					
S2	2										7								5			1		
Toilets		4																						
Director room	11				3						1								6	1		1		
Second Floor																								
Corridor	3				2						3	1												
Classrooms (1, 2)	8																		6					
Classrooms (3)	12																		12					
Room T5					36														24					
Course work T4	2																		2	1				
Room T3					10														7					
Room T2					11														6					
Room T1					6							1							5					
Toilets		4																					2	
Mathematics																								
Ground Floor																								
Corridor	8										2								1					
Research room 1	1										1	2							1	1				
Toilets	2																							
Faculty room	5																		5					
Common room	1										3									1		1		
Library	7										8	2							3	3				
Ladies waiting room	1											2			1				1	1				



Deputy registration	5																				6	3		4				
Exam B,D section	20																					9			2			
Exam A,E section	25																					9			4			
Exam section	18																					6			2			
Exam B section	18																					6			3			
Controll er of examination	20																					9						1
Exam T section	12																								5			4
Pool Office	8																					4			5			
Marine block																												
V room																												4
C room	20																											6
Director Office																												16
Common																												12
Faculty cabins	6																											36
Rest room	1																											18
Toilet	4																											4
Course in chore																												1
Stationary room	8																											4
Office	4																											8
Library	48																											6
Professor																												8
A Professor	6																											6
																												3
																												3

○ **STP**

<i>Particular</i>	<i>Ceiling Fan</i>	<i>T8</i>	<i>Air Blower</i>	<i>Collection Pump</i>	<i>Drinking water pump</i>	<i>Garden Pump</i>	<i>Clarifier Pump</i>	<i>Aeration Pump</i>
Watts	60	36	5625					
Quantity	1	1	2	2	2	2	2	2

○ **MESS**

<i>Particular</i>	<i>Ceiling Fan</i>	<i>T8</i>	<i>LED</i>	<i>Exhaust Fan</i>	<i>Exhaust Fan</i>
Watts	60	36	20	50	100
Quantity	23	5	32	3	1
Total Power (kW)	1.38	0.18	0.64	0.15	0.1

II. AIR CONDITIONER LOAD

<i>Location</i>	<i>Area</i>	<i>Type</i>	<i>Rated Capacity</i>	<i>EER</i>	<i>Star</i>	<i>Rated Power</i>	<i>Year</i>	<i>Make</i>
			TR			Watts		
Department of Physics	Magnetics	Split	1	3.8	3	1028	2019	Voltas
Department of Physics	Laboratory	Split	1.5	2.83	3	2300	2009	Voltas
Department of Physics	Laboratory	Split	1.5	2.83	3	2300	2009	Voltas
Department of Physics	Applied Optics	Window	1.5	4.5	5	892	2019	Voltas
Department of Physics	Office	Split	1.5	3.5	3	1129	2018	Voltas
Department of Physics	Office	Split	1.5	3.5	3	1129	2018	Voltas
Department of Physics	XRD	Window	1.5	4.5	5	892	2019	Voltas
Department of Physics	XRD	Window	1.5	4.5	5	892	2019	Voltas
Department of Physics	XRD	Window	1.5	4.5	5	892	2019	Voltas
Department of Physics	Gravity & Cosmology	Split	0.75	2.8	2	937.5		Voltas
Department of Physics	Nano photonics	Split	1.5	4.55	5	885	2019	Voltas
Department of Physics	Nano photonics	Split	1.5	4.55	5	885	2019	Voltas
Department of Physics	Nano photonics	Split	1.5	2.72	3	1842	2010	Godrej
Department of Physics	Nano photonics	Split	1.5	2.72	3	1842	2010	Godrej



Department of Physics	Nano photonics	Split	1.5	3.53	3	1122	2019	Voltas
Department of Physics	Nano photonics	Split	1.5	3.56	3	1109	2021	Voltas
Department of Physics	Nano photonics	Split	1.5	3.56	3	1109	2021	Lloyd
Department of Physics	Complex System group	Split	1.5	4.51	5	808	2019	Voltas
Department of Physics	DSA	Split	1.5	4.51	5	808	2019	Voltas
Department of Physics	Insta	Split	1.5	4.51	5	808	2019	Voltas
Department of Physics	Mag. Lab	Window	1			1250		Whirlpool
Department of Physics	Dream Lab	Split	1.5		3	1875		
Department of Physics	TFD	Window	1.5	2.71	3	1875	2012	Voltas
Department of Physics	TFD	Window	1	2.55	2	1314	2012	Voltas
Department of Physics	TFD	Window	1	2.55	2	1314	2012	Voltas
Department of Physics	TFD	Split	1	3.11	3	1040	2014	Videocon
Department of Physics	TFD	Split	1.5	4.51	5	893	2021	Voltas
Department of Physics	Nest	Split	1.5			1550		Voltas
Department of Physics	Nest	Split	2		5	2500		Voltas
Department of Physics	Nest	Split	2			2500		Voltas
Department of Physics	Nuclear	Split	1.5	4.5	5	892	2019	Voltas
Department of Physics	MML	Split	2	4.5	5	892	2019	Voltas
Department of Chemistry	Raman Spectroscopy room	Split	0.75	2.8	3	920	2010	Onida
Department of Chemistry	Instr. Room 1	Split	1.5	4.75	5	1043	2019	Voltas
Department of Chemistry	Instr. Room 1	Split	1	2.85	2	1230	2013	Samsung
Department of Chemistry	Instr. Lab 2	Split	1.5	3.9	3	1362	2017	Voltas
Department of Chemistry	Seminar Hall	Split	1.5			1910	2016	Voltas
Department of Chemistry	Seminar Hall	Split	1.5			1910	2016	Voltas
Department of Chemistry	Seminar Hall	Split	1.5			1910	2016	Voltas
Department of Chemistry	Seminar Hall	Split	1.5			1910	2016	Voltas
State Bank of India	ATM	Split	1	3.8	3	923	2023	Voltas
State Bank of India	ATM	Split	1	3.8	3	923	2023	Voltas
State Bank of India	Bank Hall	Split	1.5	3.51	3	1544	2019	Voltas
State Bank of India	Manager room	Split	1	3.51	3	776	2019	Voltas
State Bank of India	Bank Hall	Cassete	3			3750		Voltas
State Bank of India	Bank Hall	Cassete	3			3750		Voltas
State Bank of India	Bank Hall	Cassete	3			3750		Voltas
Department of Hindi	Auditorium	Split	1.5			1650		Voltas



Department of Hindi	Auditorium	Split	1.5			1650		Voltas
Department of Hindi	Auditorium	Split	1.5			1650		Voltas
Department of Hindi	Auditorium	Split	1.5			1650		Voltas
Department of Hindi	Auditorium	Split	1.5			1650		Voltas
Department of Hindi	Library	Tower	2.5	2.47		3565	2018	Bluestar
Department of Hindi	Library	Tower	2.5	2.47		3565	2018	Bluestar
Department of Hindi	Library	Tower	2.5	2.47		3565	2018	Bluestar
Department of Hindi	Library	Tower	2.5	2.47		3565	2018	Bluestar
Department of Biotechnology	Library	Split	2	2.55	2	2392	2011	Voltas
Department of Biotechnology	Laboratory	Split	1.5			1875		Voltas
Department of Biotechnology	Hall	Split	2			2500		Voltas
Department of Biotechnology	Hall	Split	2			2500		Voltas
Department of Biotechnology	Hall	Split	2			2500		Voltas
Department of Biotechnology	Hall	Split	2			2500		Voltas
Department of Biotechnology	Dr. Sneha	Split	1.5	3.51	5	1424	2014	Voltas
Department of Biotechnology	Dr. Sayuj	Split	1.5	3.51	5	1424	2014	Voltas
Department of Biotechnology	Dr. Sarita	Split	1.5	3.51	5	1424	2014	Voltas
Department of Biotechnology	Dr. Bhay	Split	1	3.51	3	1250		Voltas
Department of Biotechnology	Nano biotech	Split	1.5	2.68	2	1940	2010	Voltas
Department of Biotechnology	Nano biotech	Split	1.5	4.5		892		Voltas
Department of Biotechnology	Nano biotech	Split	1.5	4.5		892		Voltas
Department of Biotechnology	Microbiology	Split	2	2.75	3	2218	2011	Voltas
Department of Biotechnology	Microbiology	Split	2	3.6	3	2500		Voltas
Department of Biotechnology	Microbiology	Split	1	3.6	3	1250		Voltas
Department of Biotechnology	Microbial	Split	2	2.75	3	2218	2011	Voltas
Department of Biotechnology	Microbial	Split	2	2.75	3	2218	2011	Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	2	3.6	3	2500		Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	2	3.6	3	2500		Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	1		3	1250		Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	1		3	1250		Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	1		3	1250		Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	1		3	1250		Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	1		3	1250		Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	1		3	1250		Voltas
Department of Biotechnology	Cells & Molecular Biology	Split	1		3	1250		Voltas



Department of Biotechnology	Cells & Molecular Biology	Split	1		3	1250		Voltas
Department of Biotechnology	HOD	Split	2	5	5	959	2022	Voltas
Department of Biotechnology	Electronics	Split	1.5			1875		Voltas
Department of Biotechnology	Electronics	Split	1.5			1875		Voltas
Department of Biotechnology	Digital Electronics Board	Split	2		5	2500		Voltas
Department of Biotechnology	Digital Electronics Board	Split	1	4.5		1250		Voltas
Department of Applied Electronics	Analytical lab	Split	1	4.51	5	1430	2020	Voltas
Department of Applied Electronics	Analytical lab	Split	1	4.51	5	1430	2020	Voltas
Department of Applied Electronics	Analytical lab	Split	1	4.51	5	1430	2020	Voltas
Department of Applied Electronics	Analytical lab	Split	1	4.51	5	1430	2020	Voltas
Department of Applied Electronics	Seminar Hall	Split	1.5	3.5	5	1714	2016	Godrej
Department of Applied Electronics	Seminar Hall	Split	1.5	3.5	5	1714	2016	Godrej
Department of Applied Electronics	Room Director	Split	1	4.51	5	1250		Voltas
Department of Applied Electronics	Room Director	Split	1	4.51	5	1250		Voltas
SMS	Computer Lab	Split	1			1250		
SMS	Computer Lab	Split	1			1250		
SMS	Computer Lab	Split	1			1250		
SMS	Computer Lab	Split	1			1250		
SMS	Computer Lab	Split	1			1250		
SMS	Hall of Frame	Split	1.5	2.95	3	1728	2013	Voltas
SMS	Hall of Frame	Split	1.5	2.95	3	1728	2013	Voltas
SMS	Hall of Frame	Split	1.5	2.95	3	1728	2013	Voltas
SMS	Hall of Frame	Split	1.5	2.95	3	1728	2013	Voltas
SMS	Classroom (S5,S4)	Split	1			1250		
Mathematics	Auditorium	Split	1	4.7	5	824	2016	Daikin
Mathematics	Auditorium	Split	1	4.7	5	824	2016	Daikin
Mathematics	Auditorium	Split	1	4.7	5	824	2016	Daikin
Mathematics	Auditorium	Split	1	4.7	5	824	2016	Daikin
Mathematics	Computer Lab	Split	1	3.21		1100	2014	Bluestar
Mathematics	Computer Lab	Split	1	3.21		1100	2014	Bluestar
Central Library	Office	Split	3			4058		Voltas
Central Library	Office	Split	3			4058		Voltas
Central Library	Study Lounge	Split	1			1250		Mitsubhushi
Central Library	Study Lounge	Split	1			1250		Mitsubhushi



Central Library	Reference 2	Split	1			1250		
Central Library	Reference 2	Split	1			1250		
Central Library	Reference 2	Split	1			1250		
Central Library	Reference 2	Split	1			1250		
Central Library	E Journals	Split	1.5	3.51	3	1432	2018	Mitsubhushi
Central Library	E Journals	Split	1.5	3.51	3	1432	2018	Mitsubhushi
Central Library	E Journals	Split	1.5	3.51	3	1432	2018	Mitsubhushi
Old Building	Server room	Split	3			1800		LG
Old Building	Audio Visual & Research Centre	Split	1.5	3.72	3	1586	2018	Mitsubhushi
Old Building	Audio Visual & Research Centre	Split	1.5	3.72	3	1586	2018	Mitsubhushi
Old Building	Audio Visual & Research Centre	Split	1.5	3.72	3	1586	2018	Mitsubhushi
Old Building	Audio Visual & Research Centre	Split	1.5	3.72	3	1586	2018	Mitsubhushi
Interuniversity	Classroom	Split	1.5	3.6	3	1355	2018	Voltas
Interuniversity	Classroom	Split	1.5	3.6	3	1355	2018	Voltas
Interuniversity	Faculty post doc	Split	1	3.11	3	1076	2017	Haier
Interuniversity	Chara. Lab 2	Split	1.5	3.6	3	1355	2017	Haier
Department of Statistics	Seminar Hall	Split	1	4.51	5	1133	2020	Voltas
Department of Statistics	Seminar Hall	Split	1	4.51	5	1133	2020	Voltas
Department of Statistics	Seminar Hall	Split	1	4.51	5	1133	2020	Voltas
Department of Statistics	Seminar Hall	Split	1	4.51	5	1133	2020	Voltas
Department of Statistics	Library	Split	2	2.91	3	2113	2012	Voltas
Department of Statistics	Library	Split	2	2.91	3	2113	2012	Voltas
Department of Statistics	Library	Split	2	2.91	3	2113	2012	Voltas
Department of Statistics	Library	Split	2	2.91	3	2113	2012	Voltas
Department of Statistics	Library	Split	1.5	3.52	5	1454	2016	Voltas
Department of Statistics	Library	Split	1.5	3.52	5	1454	2016	Voltas
Department of Statistics	Faculty room	Split	1.5			1875		Voltas
Department of Statistics	Faculty room	Split	1.5			1875		Voltas
Department of Statistics	Research room	Split	1.5		5	1875		Voltas
Department of Statistics	Computer Lab	Split	1	3.51	3	1094	2019	Voltas
Department of Statistics	Computer Lab	Split	1	3.51	3	1094	2019	Voltas
SLS	Seminar Hall	Split	1.5	2.71	3	1860	2009	Voltas
SLS	Mini Hall	Split	1	4.51	5	1132	2021	Voltas
SLS	Mini Hall	Split	1	4.51	5	1132	2021	Voltas



SLS	Director room	Split	2.5			3125		Voltas
Department of English & FL	Office	Split	1			1250		Voltas
Department of English & FL	Faculty room	Split	1.5		3	1428	2018	Voltas
Department of English & FL	Classroom	Split	1			1250		Cruise
Department of English & FL	Classroom	Split	1			1250		Cruise
Department of English & FL	Lab	Split	1.5		3	1458	2018	Voltas
Department of English & FL	Classroom	Split	1.5			1759		Carrier
Department of English & FL	Classroom	Split	1.5			1759		Carrier
IPR Studies	Conference Hall	Split	1.5			1875		Voltas
IPR Studies	Conference Hall	Split	1.5			1875		Voltas
IPR Studies	Conference Hall	Split	1.5			1875		Voltas
IPR Studies	Conference Hall	Split	1.5			1875		Voltas
IPR Studies	Conference Hall	Split	1.5			1875		Voltas
IPR Studies	Visiting	Split	1.5			1875		Voltas
IPR Studies	Director room	Split	1.5			1640		Voltas
IPR Studies	Library	Split	1.5			1600		Voltas
IPR Studies	Library	Split	1.5			1600		Voltas
IPR Studies	Library	Split	1.5			1600		Voltas
IPR Studies	Library	Split	1.5			1600		Voltas
IPR Studies	Library	Split	1.5			1600		Voltas
IPR Studies	Library	Split	1.5			1600		Voltas
IPR Studies	Room	Split	1	4.75	5	839	2017	Bluestar
IPR Studies	Room	Split	1	4.75	5	839	2017	Bluestar
IPR Studies	Room	Split	1	4.75	5	839	2017	Bluestar
IPR Studies	Room	Split	1	4.75	5	839	2017	Bluestar
IPR Studies	Class	Split	1.5	4.75	5	1405	2017	Bluestar
Photonics	Director room	Split	1.5	3.51	5	1510		Voltas
Photonics	Committee	Split	2			2500		Voltas
Photonics	Committee	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas



Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Seminar Hall	Split	2			2500		Voltas
Photonics	Lab	Split	2			2375		LG
Photonics	Lab	Split	2			2375		LG
Photonics	Lab	Split	2			2375		LG
Photonics	Lab	Split	1.5	3.51	3	1411	2020	Voltas
Photonics	Lab	Split	1.5	3.51	3	1411	2020	Voltas
Photonics	Lab	Split	1.5	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	1.5	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	1.5	3.55	5	1802	2016	Voltas
Photonics	Lab	Window	1.5	2.55	2	1882	2012	Voltas
Photonics	Lab	Split	2	2.8		2510	2008	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Window	1.5	2.55	2	1882		Voltas
Photonics	Lab	Window	2			2500		Voltas
Photonics	Computer Lab	Split	1.5	2.55	2	1882	2012	Voltas
Photonics	Room	Split	2		3	1900		Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Photonics	Lab	Split	2	3.55	5	1802	2016	Voltas
Ship Technology	Seminar Hall	Split	2		5	1807	2016	Voltas
Ship Technology	Seminar Hall	Split	2		5	1807	2016	Voltas
Ship Technology	Seminar Hall	Split	2		5	1807	2016	Voltas
Ship Technology	Room 209A	Split	1.5		3	1875		Voltas
Ship Technology	Room 209A	Split	1.5		3	1875		Voltas



Ship Technology	Room 310	Split	1.5			1875		Voltas
Ship Technology	HOD	Split	1.5		3	1654	2016	Voltas
Ship Technology	HOD	Split	2		5	1985	2016	Voltas
Ship Technology	Dept room	Split	1			1250		
Ship Technology Lab Block	L05	Split	1.5			1875		Voltas
Department of Polymer science	Lab	Split	1.5		5	1510	2017	Voltas
Department of Polymer science	Lab 2	Split	1.5		5	1510	2017	Voltas
Department of Polymer science	Lab 3 - 109	Split	1.5		5	1510	2017	Voltas
Department of Polymer science	Lab 3 - 110	Split	1.5		5	1510	2017	Voltas
Department of Polymer science	Lab	Split	1		3	1250		Godrej
Centre of Budget Studies	G02	Split	1.5		5	1875	2017	Hitachi
Centre of Budget Studies	G08	Split	1.5		5	1875		Hitachi
Centre of Budget Studies	G08	Split	1.5		5	1875		Hitachi
Centre of Budget Studies	G08	Split	1.5		5	1875		Hitachi
Centre of Budget Studies	G09	Split	1.5		5	1875		Hitachi
Centre for Integrated	Room 02	Split	1.5			1875		
Centre for Integrated	Room 02	Split	1.5			1875		
Centre for Integrated	Room 08	Split	1.5			1875		
Centre for Integrated	Room 08	Split	1.5			1875		
Centre for Integrated	Room 08	Split	1.5			1875		
Centre for Integrated	Room 08	Split	1.5			1875		
Centre for Integrated	Room 08	Split	1.5			1875		
Centre for Integrated	Room 08	Split	1.5			1875		
Centre for Integrated	Room 08	Split	1.5			1875		
Centre for Integrated	Room 11	Split	1			1250		
Centre for Integrated	Room 11	Split	1			1250		
Centre for Integrated	Room 15	Split	1			1250		
Centre for Integrated	Room 20	Split	1			1250		
Centre for Integrated	Room 20	Split	1			1250		
Centre for Integrated	Room 20	Split	1			1250		
Centre for Integrated	Room 21	Split	1			1250		
Centre for Integrated	Room 21	Split	1			1250		
Centre for Integrated	Room 22	Split	1			1250		
Centre for Integrated	Room 22	Split	1			1250		
Centre for Integrated	Room 26	Split	1			1250		



Centre for Integrated	Room 26	Split	1			1250		
Centre for Integrated	Room 26	Split	1			1250		
Centre for Integrated	Room 26	Split	1			1250		
Centre for Integrated	Room 27	Split	1			1250		
Centre for Integrated	Room 27	Split	1			1250		
Centre for Integrated	Room 27	Split	1			1250		
Centre for Integrated	Room 27	Split	1			1250		
Seminar Complex	Entrance Area	Tower	3			3750		Voltas
Seminar Complex	Entrance Area	Tower	3			3750		Voltas
Seminar Complex	Entrance Area	Tower	3			3750		Voltas
Seminar Complex	Main Hall	Package	16.5			20625		Voltas
Seminar Complex	Main Hall	Package	16.5			20625		Voltas
Seminar Complex	Main Hall	Package	16.5			20625		Voltas
Seminar Complex	Main Hall	Package	16.5			20625		Voltas
Seminar Complex	Seminar Hall	Tower	3			3750		Voltas
Seminar Complex	Seminar Hall	Tower	3			3750		Voltas
Seminar Complex	Seminar Hall	Tower	3			3750		Voltas
Seminar Complex	Seminar Hall	Tower	3			3750		Voltas
Seminar Complex	Executive Hall	Split	3			3750		Bluestar
Seminar Complex	Executive Hall	Split	3			3750		Bluestar
Seminar Complex	Executive Hall	Split	3			3750		Bluestar
Seminar Complex	Room 5	Split	3			3750		
Seminar Complex	Committee Hall	Split	3			3750		Bluestar
Seminar Complex	Committee Hall	Split	3			3750		Bluestar
School of Environmental Studies	Conference room	Split	2			2500		Hitachi
School of Environmental Studies	Conference room	Split	2			2500		Hitachi
School of Environmental Studies	Conference room	Split	2			2500		Hitachi
School of Environmental Studies	Conference room	Split	2			2500		Hitachi
School of Environmental Studies	Bet Analysis	Split	2			2500		Hitachi
School of Environmental Studies	Computer room	Split	2			2500		Bluestar
School of Environmental Studies	Library	Split	2			2500		Bluestar
School of Environmental Studies	Director	Split	2			2500		Bluestar
School of Environmental Studies	AAC Lab	Split	2			2500		



School of Environmental Studies	Office	Split	1			1250		Voltas
School of Environmental Studies	GC room	Split	1			1250		
School of Environmental Studies	GLS Lab	Split	2			2500		
School of Environmental Studies	Bioremediation room	Split	1.5			1875		
School of Environmental Studies	Microplastic research room	Split	1			1250		
School of Environmental Studies	Molecular biology	Split	1.5			1875		
Admin block			1		5	1250		Voltas
Legal Office			2		5	2500		Voltas
Pay roll (A) section			1.5			1875		Voltas
Finance Office			1.5		5	1875		Voltas
Tech Foundation			1		5	1250		Panasonic
Exam confidential section			1			1250		Panasonic
Exam confidential section			1.5		5	1875		Voltas
Exam confidential section			1.5		5	1875		Voltas
Province Chancellor			1.5		5	1875		
Province Chancellor			1.5		5	1875		
Province Chancellor			1.5		5	1875		
Province Chancellor			1.5		5	1875		
Province Chancellor			1.5		5	1875		
Senate hall			1.5			1875		
DOA Confidential room			1			1250		Voltas
DOA Confidential room			3			3750		Voltas
Director			1		3	1250		
Syndicate hall			1.5			1875		Voltas
VC			1		5	1250		
UC room			5.5			6875		
V/C conference room			1.5			1875		Panasonic
V/C room			1			1250		
UPS room			1.5		5	1875		Voltas
ARIS lab			1.5			1875		Voltas
ARIS lab			1		3	1250		Voltas
International rec			1.5			1875		Voltas
International rec			2		5	2500		Voltas
International rec			2		5	2500		Voltas



International rec			2		5	2500		Voltas
IQAC			1.5		3	1875		
IQAC			1.5		3	1875		
IQAC			1.5		5	1875		
Controller of examination			1			1250		Panasonic
Controller of examination			1.5			1875		Panasonic
Marine block			1.5			1875		Voltas
C room			2			2500		Voltas
C room			2			2500		Voltas
Course in chore			1		3	1250		
Simulation lab			1.5			1875		Voltas
Lab 108			1.5		5	1875		Voltas
Seminar hall			2			2500		Voltas

III. OTHER POWER LOAD

<i>Particulars</i>	<i>PC</i>	<i>Printer</i>	<i>Xerox</i>	<i>3 in 1</i>	<i>Projector</i>	<i>Amplifier</i>	<i>Kettle</i>	<i>Induction</i>	<i>Water Dispenser</i>	<i>TV</i>	<i>Cooler</i>	<i>Fridge</i>
<i>Watts</i>	<i>110</i>	<i>250</i>	<i>300</i>	<i>300</i>	<i>200</i>	<i>150</i>	<i>1500</i>	<i>1500</i>	<i>450</i>	<i>110</i>	<i>250</i>	<i>350</i>
<i>Total Nos</i>	490	71	22	15	25	2	1	5	8	15	9	6
<i>Total kW</i>	53.9	17.75	6.6	4.5	5	0.3	1.5	7.5	3.6	1.65	2.25	2.1
<i>Total</i>	<i>106.65 kW</i>											

ANNEXURE-3

LIST OF INSTRUMENTS

Sl.no	Equipment description	Make & model
1	Power Energy & Harmonic Analyser	Krykard ALM 31
2	Power Energy & Harmonic Analyser	Krykard ALM 35

IIABBREVIATIONS

APFC	:	Automatic Power factor Control
AVG	:	Average
BEE	:	Bureau of energy efficiency
BH	:	Boys Hostel
CO ₂	:	Carbon dioxide
KSEB	:	Kerala State Electricity Board.
DB	:	Distribution Board
EC	:	Energy Conservation
IEEE	:	The Institute of electrical and electronics engineers
IS	:	Indian Standard
kL	:	kilo Litre
KVA	:	kilo Volt Ampere
kVAh	:	kilo volt Ampere Hour
kVAr	:	kilo volt ampere
kW	:	kilo Watts
kWh	:	kilo watt hour
LH	:	Ladies Hostel
LPG	:	Liquified Petroleum Gas
LT	:	Low tension
MAX	:	Maximum
NSS	:	National Service Scheme
SLD	:	Single Line Diagram
THD	:	Total Harmonic Distortion
TR	:	Transformer


REFERENCES:

- Handbook on energy audit and environment management by TERI.
- Bureau of Energy Efficiency (BEE) books for certification of Energy Auditors & Managers.



CERTIFICATES

I. BEE Accreditation Certificate





II. EMC Empanelment certificate



Energy Management Centre - Kerala (Department of Power, Govt of Kerala)

CERTIFICATE OF EMPANELMENT

This is to certify that **M/s.Athul Energy Consultants Pvt Ltd**(4/2, Capital Legend Building, Korapath Lane, Round North, Thrissur)is empanelled as Energy Audit firm in Energy Management Centre Kerala to conduct mandatory energy audit as per Government of Kerala G.O (Rt) No.2/2011/PD dated 01.01.2011.

Empanelment No:
EMCEEA-0811F-3

Scope/Area	Building	Industry -Electrical	Industry Thermal
	Yes	Yes	Yes

This empanelment is valid up to 01/02/2024

Issuing Date: 02/02/2021

Place: Thiruvananthapuram

Director,
Energy Management Centre - Kerala